



| | | | | | | | |
|-------------|----------------|------------------|-----------|----------------------|---------|---------------|--|
| Model No | | Working pressure | | Working T emperature | | Dimension(mm) | |
| 1354 | | 150psi(10.5BAR) | | 1-49centigrade | | Ø 325x1345 | |
| Top Opening | Bottom Opening | Water flow rate | Volume | Net H | Total H | | |
| 2.5"-NPSM | | 2.0~2.5{ TPH } | 102Liters | 1335 | 1345 | | |

NOTES:

- 1 . TANK MUST MEET ALL APPLICABLE SPECIFICATIONS OF NSF/ANSI 044 STANDARD, LATEST REVISION.
- 2 . OPERATING SPECIFICATIONS:
 - A. MAXIMUM WORKING PRESSURE - 150 PSI (10.5BAR)
 - B. TEMPERATURE RANGE - 34-120° F (1-49°C)
 - C. MAXIMUM VACUUM - 5"Hg (127mm Hg)
- 3 . VISUAL LINER INSPECTION
 - A. NO MORE THAN 10 INTERNAL OR EXTERNAL BLEMISHES OR BURNT DEBRIS.
 - B. NO INTERNAL OR EXTERNAL BLEMISHES OR BURNT DEBRIS LARGER THAN 3×3mm.
 - C. NO INTERNAL BLEMISHES OR BURNT DEBRIS ALLOWED.
- 4 . ALL GLASS STRANDS FROM FIBERGLASS LINER TO BE BONDED AND COVERED.
- 5 . SURFACE TO BE FREE OF NICKS, SCRATCHES, RESIN AND GLASS.
- 6 . SURFACE FINISH.
- 7 . DIMENSIONS IN PARENTHESIS ARE REFERENCE ONLY.
- 8 . DIMENSIONS IN SQUARE PARENTHESIS ARE INCH UNIT.
- 9 . USING A STANDARD LEVEL WITH TANK POSITIONED ON A LEVEL SURFACE, DATUM B TO BE PARALLEL WITH DATUM A. BUBBLE OF LEVEL MUST FALL COMPLETELY WITHIN LINES WHEN MEASURED AT 90° INTERVALS.

| | | | | | |
|--|------|--------------------------------|---------------|---------------------|--|
| VERSION No. | | DESCRIPTION OF CHANGES: | | | |
| REFERENTIAL PLASTIC SHRINKAGE (IF NECESSARY): | | MODEL: FT 1354 | | | |
| SIGNATURE | | PURELINE | | | |
| NAME | DATE | | | | |
| DESIGN | | SCALE | MATERIAL | MODEL | |
| INSPECTION | | | | DESCRIPTION | |
| APPROVAL | | QUANTITY | SMOOTHNESS | FRP PRESSURE VESSEL | |
| THIS PRODUCT DRAWING CAN NOT BE COPIED AND/OR USED WITHOUT PRIOR WRITTEN APPROVAL OF WAVE CYBER. | | PROJECTION | COMPUTER CODE | | |
| | | DO NOT MEASURE THE DIMENSIONS. | UNIT: MM | TOTAL PAGE: 1 | |